

Akce : ZS Zebrak - nastavba pavilonu c.5
Datum : 30. 5.2024

Teplota topne vody - privodni : 70.0 oC
vratne : 55.0 oC
Procento vykonu pro navrh teles : 100.0

Vypis pro okruh c. 1

Mistnost cislo popis	Soustava teplota oC oC/oC	Otopne teleso --	delka mm	vodni objem dm3	tepelny vykon W
101 WC hosi	15 70/55	21-050070-60-VK	700	3.6	726
102 WC divky	15 70/55	21-050090-60-VK	900	4.6	933
103 schodiste	15 70/55	33-090070-60-VK	700	8.8	2158
201 ucebna	20 70/55	11-050160-60-VK	1600	4.3	1099
201 ucebna	20 70/55	11-050160-60-VK	1600	4.3	1099
201 ucebna	20 70/55	11-050160-60-VK	1600	4.3	1099
202 ucebna	20 70/55	11-050160-60-VK	1600	4.3	1099
202 ucebna	20 70/55	11-050160-60-VK	1600	4.3	1099
202 ucebna	20 70/55	11-050160-60-VK	1600	4.3	1099
203 kabinet	20 70/55	21-050110-60-VK	1100	5.6	981
204 chodba	15 70/55	11-050120-60-VK	1200	3.2	957
204 chodba	15 70/55	11-090080-60-VK	800	3.4	1036
205 spojov. krcek	15 70/55	21-050140-60-VK	1400	7.1	1452

Otopne teleso --	vyska mm	delka mm	cena Kc/ks	Celkem pocet kusu	Celkem cena Kc	vodni objem dm3	tepelny vykon W
11-050120-60-VK	500	1200	0	1	0	3.2	956
11-050160-60-VK	500	1600	0	6	0	25.9	6594
21-050070-60-VK	500	700	0	1	0	3.6	726
21-050090-60-VK	500	900	0	1	0	4.6	933
21-050110-60-VK	500	1100	0	1	0	5.6	981
21-050140-60-VK	500	1400	0	1	0	7.1	1451
11-090080-60-VK	900	800	0	1	0	3.4	1035
33-090070-60-VK	900	700	0	1	0	8.8	2157
Celkem okruh c. 1				13	0	62.3	14833
Celkem objekt				13	0	62.3	14833